



## SECTION 10 51 13 - METAL LOCKERS

### PART 1 GENERAL

#### 1.1 SECTION INCLUDES

- A. DESCRIPTION: Furnish and install "Superior Classic KD Lockers", complete, as shown and specified per contract documents.

#### 1.2 RELATED WORK SPECIFIED ELSEWHERE:

- A. Concrete: Section 03 10 00
- B. Rough Carpentry: Section 06 10 00
- C. Finish Carpentry: Section 06 20 00

#### 1.3 SUBMITTALS

- A. GENERAL: Refer to Section 01 30 00 ADMINISTRATIVE REQUIREMENTS - SUBMITTALS
- B. SHOP DRAWINGS: Submit drawings showing locker types, sizes, quantities, including all necessary details relating to anchoring, trim installation and relationship to adjacent surfaces.
- C. COLOR CHARTS: Provide color charts showing manufacturer's available colors (minimum 24). Provide metal samples if requested.
- D. NUMBERING: Locker numbering sequence will be provided by the approving authority and noted on approved shop drawings returned to the locker contractor.

#### 1.4 QUALITY ASSURANCE

- A. MANUFACTURING STANDARD: Provide metal lockers that are standard products of a single manufacturer, with interchangeable like parts. Include necessary mounting accessories, fittings, and fastenings.
- B. FABRICATOR QUALIFICATIONS: Firm experience (minimum 5 years) in successfully producing the type of metal lockers indicated for this project, with sufficient production capacity to produce required units without causing delay in the work.
- C. INSTALLER QUALIFICATIONS: Engage an experienced (minimum 2 years) installer who has successfully completed installation of the type of metal lockers and extent to that indicated for this project.

#### 1.5 PRODUCT HANDLING

- A. GENERAL: All work shall be fabricated in ample time so as to not delay construction process.
- B. DELIVERY: All materials shall be delivered to the site at such a time as required for proper coordination of the work. Materials are to be received in the manufacturer's original, unopened packages and shall bear the manufacturer's label.

- C. STORAGE: Store all materials in a dry and well ventilated place adequately protected from the elements.

## 1.6 WARRANTY

- A. Knock-Down Lockers are covered against all defects in materials and workmanship excluding finish, damage resulting from deliberate destruction and vandalism under this section for a period of 2 years.

## PART 2 PRODUCTS

### 2.1 MANUFACTURERS

- A. AVAILABLE MANUFACTURERS: Subject to compliance with the design, material, method of fabrication and installation as required in this specification section or modified as shown on drawings. Manufacturers offering products which may be incorporated in the work include the following: List Industries Inc. (Basis of Design)

### 2.2 LOCKER TYPES

- A. GENERAL: Lockers shall be "SUPERIOR CLASSIC KD LOCKERS" as manufactured by List industries Inc. or approved equal.

1. Type: - Tier
2. Size: - wide x - deep x - high

- B. SUPERIOR CLASSIC KD LOCKERS:

1. Box Doors: fabricated from single sheet prime 18 gauge with single bends at top, bottom and sides
2. Wardrobe Doors: fabricated from single sheet prime 16 gauge (18 gauge for doors 9" wide as well as Two-Person and Duplex doors) with single bends at top and bottom and double bends at the sides
3. Frame: Fabricate frame of 16 gauge (minimum) channels welded to horizontal channels top and bottom with integral continuous vertical door stop/strike formed on both latch and hinge side.
4. Sides: 24 gauge solid sheet steel.
5. Tops, Bottoms, Shelves: 24 gauge solid sheet steel
6. Backs: 24 gauge solid sheet steel

### 2.3 FABRICATION

- A. MATERIALS

1. Steel Sheet: All sheet steel used in fabrication shall be prime grade free from scale and imperfections and capable of taking a heavy coat of custom blend powder coat.
2. Fasteners: Cadmium, zinc or nickel plated steel; bolt heads, slotless type; self locking nuts or lock washers.
3. Number Plates: To be aluminum with not less that 3/8" high etched numbers attached to door with two aluminum rivets.

4. CONSTRUCTION: Lockers shall be "Superior Classic KD Wardrobe and Box Lockers" as manufactured by List Industries Inc. or approved equal. Fabricate lockers square, rigid and without warp, with metal faces flat and free from dents or distortion. Make all exposed metal edges safe to touch. Weld frame members together to form rigid, one-piece structure. Weld, bolt, or rivet other joints and connections as standard with manufacturer. Grind exposed welds flush. Do not expose bolts or rivet heads on fronts of locker doors or frames except for fastening of number plates and recessed handle.
5. FRAME: Fabricate of 16 gauge (minimum) channels, with integral continuous door stop/strike formed on both latch and hinge side vertical members. Cross frame members of 16 gauge channel shapes, including intermediate cross frame members on double and triple tier (frames with doors over 18" high) lockers shall be securely welded to the vertical framing members to ensure rigidity. Rubber bumpers shall be provided to cushion door closing.
6. TOP, BOTTOM AND INTERMEDIATE TIER DIVIDERS: shall be of 24 gauge (minimum) sheet steel with single return bends at all sides. Bolt top and bottom to front horizontal frame members at not less than one place in addition to side panels..
7. BACK and SIDES: Fabricate back and sides of 24 gauge (minimum) sheet steel, with double flanged connections extending full height.
8. WARDROBE DOORS: Doors 20" high and over to be fabricated from single sheet prime 16 gauge (18 gauge for doors 9" wide as well as Two-Person and Duplex doors) with single bends at top and bottom and double bends at the sides. The channel formed by the double bend at the latch side is designed to fully conceal the lock bar. Doors shall be louvered. Upper compartment doors of Two-Person shall be plain (non-louvered).
9. BOX DOORS: Doors 18" high and under to be fabricated from single sheet prime 18 gauge with single bends at top, bottom and sides. Doors shall include a combination friction catch door pull. Padlock Strike Plates are optional. Doors shall be fabricated to accept a built-in combination lock or padlock. Doors with projecting spring latches shall not be acceptable. Doors shall be louvered.LATCHING/HANDLE: Doors shall include a single point friction catch door pull. Padlock Strike Plates are optional. Doors shall be fabricated to accept a built-in combination lock or padlock.
- 10.HANDLE: All wardrobe doors shall have a recessed 304 stainless steel, deep drawn handle shaped to receive a padlock or built-in combination lock. The recess pan shall be deep enough to have the lock be flush with the outer door face. Box doors shall be equipped with a combination friction catch door pull as stated above.
- 11.LATCHING: The latching mechanism for wardrobe doors shall be finger lift control type constructed of 14 gauge (minimum) steel with a nylon cover that has a generous finger pull. Spring activated nylon slide latches shall be completely enclosed in the lock channel allowing doors to close with the lock in the locked position. Locking devise shall be designed for use with either built-in combination locks or padlocks. Latch hooks shall be securely welded to the vertical frame channel on the strike side to engage the nylon slide latches. Three latch hooks for doors 48" and higher, two latch hooks for doors under 48" high.
- 12.DOOR HINGES: All doors shall include a 16 gauge continuous piano hinge welded to the door and riveted to the frame. All doors to be right hand, side hinged.

#### 2.4 LOCKER ACCESSORIES:

- A. LOCKS (If required): Shall be master keyed to one system for the entire project
- B. EQUIPMENT: Furnish each locker with the following items, unless otherwise shown.
  1. Finished End Panels (If required): Shall be "Boxed" type formed from 16 gauge cold rolled steel with 1" O.D. double bends on sides and a single bend at top and bottom with no exposed holes or

bolts. If lockers have slope tops, end panels must be formed with slope at top to cover the ends of the slope tops. Finished to match lockers. Provide at all exposed ends.

2. Continuous Slope Tops (If required): Not less than 18 gauge sheet steel approximately 18 degrees pitch, in lengths as long as practical but not less than four lockers. To be installed in addition to the locker flat top with end closures for support. Finished to match lockers.
  3. Fillers (if required): Provide where indicated, of not less than 16 gauge sheet steel, factory fabricated and finished to match lockers.
- C. FINISHING: All locker parts to be cleaned and coated after fabrication with a seven stage zinc/iron phosphate solution to inhibit corrosion, followed by a coat of high grade custom blend powder electrostatically sprayed and baked at 350 degrees Fahrenheit for a minimum of 20 minutes to provide a tough durable finish. Color to be selected from manufacturer's standard list of colors. Interior components to be painted to match the exterior color.
- D. Lockers shall be GREENGUARD GOLD Certified.

## PART 3 EXECUTION

### 3.1 INSTALLATION

- A. GENERAL: Installation shall be in strict conformance with referenced standards, the manufacturer's written directions, as shown on the drawings and as herein specified.
- B. PLACEMENT: Lockers shall be set in place, plumb, level, rigid, flush and securely attached to the wall (or bolted together if back-to-back) and anchored to the floor or base according to manufacturer's specifications.
- C. ANCHORAGE: About 48" o.c., unless otherwise recommended by manufacturer, and apply where necessary to avoid metal distortion, using concealed fasteners. Friction cups are not acceptable.
- D. TRIM: Sloping tops, metal fillers and end panels shall be installed using concealed fasteners. Provide flush, hairline joints against adjacent surfaces.

### 3.2 ADJUSTMENT

- A. GENERAL: Upon completion of installation, inspect lockers and adjust as necessary for proper door operation. Touch-up scratches and abrasions to match original finish.

END OF SECTION